

IAPMO R&T OCEANA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia



IAPMO R&T Oceana is a product certification body which inspects and arranges for the independent laboratory testing of samples taken from the manufacturer's stock or from the market or a combination of both, to verify compliance of the requirements of applicable Standards and Specifications. This activity is coupled with periodic surveillance of the manufacturer's factory and any major subcontractor's site/s as well as the assessment of the manufacturer's Quality Assurance System. This certification is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO R&T Oceana of the product acceptance by Authorities Having Jurisdiction.

CERTIFICATE OF CONFORMITY

IAPMO R&T Oceana hereby grants to:

Jets Vacuum AS

Hareidsmyrane 1, Hareid, N-6060, Norway

the right to use the WaterMark in accordance with the ABCB Manual for the WaterMark Certification Scheme; – Australian Standards; WaterMark Technical Specifications; and the Plumbing Code of Australia; only in respect of the certified product as described in the WaterMark Certificate of Conformity – Schedule of Certified Product (Refer also IAPMO Product Listing Directory). The Certificate is granted subject to the rules governing the WaterMark Certification Scheme and the Terms and Conditions of the Approved User Agreement and IAPMO Oceana's WaterMark Governance Rules.

Evaluated to:

SA TS 100:2018

Vacuum WC pans, vacuum urinals and interface valves intended for use with vacuum drainage systems and designs

Manufacturer:

Jets Vacuum AS

Licence No.: WM-022505

First Certified: 20 January 2016

Certification Date: 20 November 2020

Expiry Date: 19 November 2025

Chief Executive Officer of The IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO R&T Oceana, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO R&T Oceana. Any alteration of this certificate could be grounds for revocation of this certification.

"This certificate is issued by a JAS-ANZ accredited Conformity Assessment Body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate."



WATERMARK CERTIFICATE OF CONFORMITY

SCHEDULE OF CERTIFIED PRODUCT



Certificate Holder: Jets Vacuum AS
Address: Hareidsmyrane 1, Hareid, N-6060, Norway
Manufacturer: Jets Vacuum AS

Licence No: WM-022505
Certification Date: 20 November 2020
Expiry Date: 19 November 2025
First Certified: 20 January 2016
Standards: SA TS 100:2018
Title: Vacuum WC pans, vacuum urinals and interface valves intended for use with vacuum drainage systems and designs

Brand Name	Model Name	Model ID	Product Type	Product Description	Matching Interface Valve	Matching Rinse Valve	Rinse Volume	Max Operating Pressure	Min Operating Pressure	Max Operating Temperature	Material
Jets	50M Floor	T0650PO	Vacuum pan and interface valve	Floor mounted pedestal vacuum toilet with VFD valve assembly (integrated interface and rinse valve). Supplied with WMK flexible inlet hose. Optionally supplied with CFD valve assembly WELS RATING 6	054100961, 054100960, 054100962, 054100965, 054100970, 054100971, 055100150	054100961, 054100960, 054100962, 054100965, 054100970, 054100971, 055100150	0.9L	200kPa	700kPa	60°C	Vitreous China
Jets	59M Wall	T0659PO	Vacuum pan and interface valve	Wall mounted vacuum toilet with VFD valve assembly (integrated interface and rinse valve). Supplied with WMK flexible inlet hose. Optionally supplied with CFD valve assembly WELS RATING 6	054100961, 054100960, 054100962, 054100965, 054100970, 054100971, 055100150	054100961, 054100960, 054100962, 054100965, 054100970, 054100971, 055100150	0.9L	200kPa	700kPa	60°C	Vitreous China
Jets	Jade Wall	TO662PO	Vacuum pan and interface valve	Wall mounted vacuum toilet with VFD valve assembly (integrated interface and rinse valve). Supplied with WMK flexible inlet hose. Optionally supplied with CFD valve assembly WELS RATING 6	055100150, 054100961, 054100960, 054100962, 054100965, 054100970, 054100971	055100150, 054100961, 054100960, 054100962, 054100965, 054100970, 054100971	0.5L	200kPa	700kPa	60°C	Vitreous China
Jets	Jade Floor	TO661PO	Vacuum pan and interface valve	Floor mounted pedestal vacuum toilet with VFD valve assembly (integrated interface and rinse valve). Supplied with WMK flexible inlet hose. Optionally supplied with CFD valve assembly WELS RATING 6	055100150, 054100961, 054100960, 054100962, 054100965, 054100970, 054100971	055100150, 054100961, 054100960, 054100962, 054100965, 054100970, 054100971	0.5L	200kPa	700kPa	60°C	Vitreous China
Jets	Urinal JETS 722	UR722PO	Vacuum urinal and interface valve	Single-stall vacuum urinal with VFD valve assembly (integrated interface and rinse valve). Supplied with WMK flexible inlet hose WELS RATING 5	054100970	054100970	0.59L @ 230kPa	200kPa	700kPa	60°C	Vitreous China
Jets	VD Valve	054100955	Interface valve for use with vacuum drainage system	Interface valve for remote installation onto a vacuum drainage system. Vacuum operated.	N/A	N/A	N/A	-35kPa	-70kPa	60°C	Plastic
Jets	ED Valve	052508031	Interface valve for use with vacuum drainage system	Interface valve for remote installation onto a vacuum drainage system. Electronically operated, 24VDC.	N/A	N/A	N/A	-35kPa	-70kPa	60°C	Plastic
Jets	ED Valve	052508030	Interface valve for use with vacuum drainage system	Interface valve for remote installation onto a vacuum drainage system. Electronically operated, 230V.	N/A	N/A	N/A	-35kPa	-70kPa	60°C	Plastic

A handwritten signature in black ink, appearing to read "Ron Chaney". The signature is written in a cursive style with a horizontal line underneath it.

Chief Executive Officer of The IAPMO Group